




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Scala Hanging		
Size [mm]:	w = 1207	h = 1600	d = 20

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.84
250	1.35
500	2.22
1000	3.06
2000	3.68
4000	3.69
N₁₀ = 4.5	



ORIGINAL TEST REPORT	DATE OF REPORT
KTH-MWL LW201609_R3	2016-09-23

