




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Sahara 4 pcs		
<b>Size [mm]:</b>	w = 880	h = 880	d = 55

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0
250	0.01
500	0.02
1000	0.01
2000	0.01
4000	0.01
<b>N<sub>10</sub> = 1000</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 18-720-M11	2018-12-13

