




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Wall		
Size [mm]:	w = 1000	h = 1000	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.01
125	0.14
250	0.12
500	0.25
1000	0.32
2000	0.34
4000	0.37
N₁₀ = 40	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-360-M6	2018-01-16

