




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Soneo Wall		
<b>Size [mm]:</b>	w = 1000	h = 1000	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.3
250	0.45
500	0.7
1000	0.8
2000	0.85
4000	0.8
<b>N<sub>10</sub> = 14.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
SP report PX04109B	2010-08-02

