




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Wall		
Size [mm]:	w = 1000	h = 1000	d = 100

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.2
125	0.7
250	1.2
500	1.3
1000	1.1
2000	1.2
4000	1.2
N₁₀ = 9.1	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 15-240-M3	2016-01-12

