




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Soneo Wall		
<b>Size [mm]:</b>	w = 1000	h = 1000	d = 100

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.2
125	0.7
250	1.2
500	1.3
1000	1.1
2000	1.2
4000	1.2
<b>N<sub>10</sub> = 9.1</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 15-240-M3	2016-01-12

