




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Stitch		
<b>Size [mm]:</b>	w = 1000	h = 1465	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.4
125	0.8
250	1.7
500	2.5
1000	2.8
2000	3
4000	3.1
<b>N<sub>10</sub> = 4</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF TEST</b>
Akustikverkstan report 13-137-M2	2013-11-12

