




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Stitch		
Size [mm]:	w = 1000	h = 1465	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	0.8
250	1.7
500	2.5
1000	2.8
2000	3
4000	3.1
N₁₀ = 4	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 13-137-M2	2013-11-12

