




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	Sound Off Wall		
Size [mm]:	w = 1400	h = 1400	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	0.8
250	1.1
500	1.7
1000	2.1
2000	2.3
4000	2.7
N₁₀ = 5.9	



ORIGINAL TEST REPORT	DATE OF TEST
Akustikverkstan report 16-239-M19	2017-01-16

