




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	ScreenIT A30 Wall Art		
Size [mm]:	w = 1500	h = 1200	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.07
125	0.33
250	0.7
500	1.33
1000	1.77
2000	1.93
4000	1.7
N₁₀ = 7.5	



ORIGINAL TEST REPORT	DATE OF TEST
SP report 4P03825 /Annex 4	2014-06-08

