


**SOUND ABSORPTION AREA FOR OBJECT**

Measured and evaluated according to SS-EN ISO 354 and SS 25269

CLIENT: Kinnarps AB

OBJECT: Kinnarps PRIM office screen, 1600×2000 mm<sup>2</sup>. Absorptive area 3,20 m<sup>2</sup> on each side of screen.

1/3 octave band (Hz)	Equivalent sound absorption area / object (m <sup>2</sup> Sabin)	
	1/3 octave band	Octave band
50	0,6	
63	0,6	0,6
80	0,6	
100	0,6	
125	1,5	1,8
160	2,7	
200	3	
250	3,3	3,6
315	3,9	
400	4,5	
500	5,4	5,1
630	5,4	
800	6	
1000	6	6
1250	6	
1600	6	
2000	6,3	6
2500	6	
3150	6	
4000	6,3	6,3
5000	6,3	



**CONDITIONS**

Date of test: 2014-03-07  
Date: 2014-04-30

Object surface: 3,20 m<sup>2</sup>  
Rev. room volume: 200 m<sup>3</sup>

Test report: 4P01287 (dated 19 March 2014, SP, Sweden)  
Signature: Klas Hagberg